

EU type examination certificate

EU-Baumusterprüfbescheinigung

CE-0085CT0009

Product Identification No.
Produkt-Identnummer

Field of Application <i>Anwendungsbereich</i>	EU Gas Appliances Regulation (EU/2016/426) <i>EU-Gasgeräteverordnung (EU/2016/426)</i>
Distributor <i>Vertreiber</i>	BDR THERMEA France S.A.S. 57, rue de la Gare, F-67580 Mertzwiller
Product Category <i>Produktart</i>	Boilers with flue systems: Condensing water heater (3202)
Product Description <i>Produktbezeichnung</i>	gas fired condensing boiler
Model <i>Modell</i>	OERTLI GSC150-...
Countries of Destination <i>Bestimmungsländer</i>	AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MT, NL, NO, PL, PT, RO, RS, RU, SE, SI, SK, TR, UA
Test Reports <i>Prüfberichte</i>	supplement test: 161315aZ3/17865 from 27.02.2019 (GWI)
Test Basis <i>Prüfgrundlagen</i>	EU/2016/426 A III B (09.03.2016) DIN EN 15502-1 (01.10.2015) DIN EN 15502-2-1 (01.09.2017)
Date of Expiry / File No. <i>Ablaufdatum / AZ</i>	12.03.2028 / 19-0210-GER



16.05.2019 Rie C-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 and notified by the government of the Federal Republic of Germany for certification of gas appliances under EU Regulation

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte und von der Deutschen Bundesregierung benannte Stelle für die Zertifizierung von Gasgeräten gemäß EU-Verordnung EU/2016/426.


Deutsche
Akkreditierungsstelle
D-ZE-16028-01-01DVGW CERT GmbH
ZertifizierungsstelleJosef-Wirmer-Str. 1-3
53123 BonnTel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993www.dvgw-cert.com
info@dvgw-cert.com

Appliance Categories <i>Gerätekatégorien</i>	Supply Pressures <i>Versorgungsdrücke</i>	Countries of Destination <i>Bestimmungsländer</i>	Remarks <i>Bemerkungen</i>
I2E(R)	20/25 mbar	BE	
I2E(S)	20/25 mbar	BE	
I2H	20 mbar	LV	
I3B/P	30 mbar	MT	
I3P	37 mbar	BE	
I3P	50 mbar	BE	
II2E3B/P	20, 37 mbar	PL	only for type ...115
II2E3P	20, 50 mbar	LU	
II2EK3B/P	20/25, 30 mbar	NL	
II2EK3P	20/25, 50 mbar	NL	
II2ELL3B/P	20, 50 mbar	DE	
II2ELL3P	20, 30 mbar	DE	
II2ELw3B/P	20, 30 mbar	PL	only for type ...90
II2ELwLs3B/P	20,20,13, 30 mbar	PL	only for types ...45 and ...65
II2Esi3B/P	20/25, 30 mbar	FR	
II2Esi3B/P	20/25, 50 mbar	FR	
II2Esi3P	20/25, 37 mbar	FR	
II2H3B/P	20, 30 mbar	CY, CZ, DK, EE, FI, GR, IT, LT, NO, SE, SI, SK, TR	
II2H3B/P	20, 37 mbar	CZ	
II2H3B/P	20, 50 mbar	AT, CH, CZ, GR, SK, TR	
II2H3P	20, 30 mbar	IS, RO	
II2H3P	20, 37 mbar	CH, ES, GB, GR, HR, IE, IT, LT, PT, SI, SK, TR	
II2H3P	20, 50 mbar	GB	
II2HS3B/P	20/25, 30 mbar	HU	
II2L3B/P	25, 30 mbar	NL	
II2L3P	25, 50 mbar	NL	

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
GSC150-45	nominal heat output: 8,0...40,8 kW heat input (Hi): 8,2...41,2 kW	
GSC150-65	nominal heat output: 12,0...61,5 kW heat input (Hi): 12,2...62,0 kW	
GSC150-90	nominal heat output: 14,1...84,2 kW heat input (Hi): 14,6...86,0 kW	
GSC150-115	nominal heat output: 18,9...103,9 kW heat input (Hi): 19,6...107,0 kW	

Hints of Utilization /Remarks

Verwendungshinweise / Bemerkungen

electrical data: 230 V AC, 50 Hz, IPX1B

flue types B23, B23P, B33, C13(x), C33(x), C43(x), C53(x), C63(x), C83(x) and C93(x): according to installation manual "GSC150"

Additionally tested appliance categories, supply pressures and countries of destination:

RS: II2H3P (20, 30 mbar)

BG: II2H3P (20, 37 mbar)

BG: II2H3P (20, 50 mbar)

RU: II2H3B/P (20, 30 mbar)

RU: II2H3B/P (20, 50 mbar)

UA: I2H (20 mbar)

In the non-EU countries the conformity approval will be accepted if the Gas Appliance Regulation EU/2016/426 is transferred into national law by this countries.

DVG